

Data sheet

# Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

Application



Robustly built and designed to meet the rigours of the commercial and industrial sectors, a comprehensive range of RA2000 radiator thermostats is available for practically all systems and installation conditions.

Sensors and valve bodies are packed separately so that they can be mixed and matched for any duty.

RA-FN fixed capacity valve bodies are used in two-pipe heating systems.

Versions: straight and angled in sizes from DN 10 to DN 25 and horizontal angled in sizes from DN 10 to DN 20.

RA-G high capacity valve bodies are used in gravity systems or in pumped one-pipe systems. Versions: straight and angled in sizes from DN 15 to DN 25.

RA-FN and RA-G valve bodies are made of nickelplated brass. The pressure pin of the gland seal is of chromium steel and works in a lifetime lubricated O-ring seal. The gland assembly can be replaced without draining down the system.

The protective cap supplied with each new valve may be used for manual control during installation only. It should not be used as isolation device. A manual shut off device is available as a spare part.

Sensors are available as in standard and tamperproof versions, with built-in or remote sensors. Remote temperature adjusters are available with 2, 5 and 8 m of capillary tube.

All sensors have facilities for temperature range limiting and locking.

#### **RA2000 features:**

- Robust construction
- Accurate temperature control
- Temperature range limiting and locking
- Tamper resistant models
- Bulit-in and remote sensor models
- Remote temperature adjustment models
- · Low temperature models



Danfoss

RA2000 013G5062 remote temperature adjuster



**RA-FN** horizontal angle



## Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

## System



## Code Nos. and Technical Data for RA2000 sensors

Туре	Sensor	Temp. range <sup>1)</sup> Xp = 2K	Code no.
RA 2910	Built-in sensor	5 - 26 °C	013G2910
RA 2912	Remote sensor, 0 - 2 m capillary tube <sup>2)</sup>	5 - 26 °C	013G2912
RA 2914	Built-in sensor, limited temperature range	5 - 22 °C	013G2914
RA 2916	Remote sensor, 0 - 2 m capillary tube <sup>2)</sup> , limited temperature range	5 - 22 °C	013G2916
RA 2920	Built-in sensor, tamperproof model	5 - 26 °C	013G2920
RA 2922	Remote sensor, 0 - 2 m capillary tube <sup>2)</sup> , tamperproof model	5 - 26 °C	013G2922
RA 5062	Remote temperature adjuster <sup>3)</sup> , 0 - 2 m capillary tube <sup>2)</sup>	8 - 28 °C	013G5062
RA 5065	Remote temperature adjuster <sup>3)</sup> , 0 - 5 m capillary tube <sup>2)</sup>	8 - 28 °C	013G5065
RA 5068	Remote temperature adjuster <sup>3)</sup> , 0 - 8 m capillary tube <sup>2)</sup>	8 - 28 °C	013G5068

<sup>1)</sup> Temperatures shown are for units with built-in sensors which are subject to influence from radiation and flow temperature. Without these influences, max. temperature is 2 °C higher at design load condition.

<sup>2)</sup> Remote sensors are supplied with all the capillary tube coiled within the sensor. When installing the sensor, only the length required should be uncoiled.

<sup>3)</sup> Remote temperature adjusters are supplied with adapters for RA-valves. Adaptors for older valves can be ordered separately: RAVL-adaptor, code no. 013G5192 and RAV-adaptor, code no. 013G5193.



## Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

#### Code Nos. and Technical Data for RA-FN valves

Туре		Conne	ections	$k_v$ -value <sup>1)</sup> (m <sup>3</sup> /h at 1 bar pressure drop) P-band = K								
	Design	Inlet	Outlet	0.5K	1.0K	1.5K	2.0K	k <sub>vs</sub>				
RA-FN 10	angle	Rp 3/8	R 3/8	0.17	0.34	0.47	0.56	0.65				
RA-FN 10	straight	Rp 3/8	R 3/8	0.17	0.34	0.47	0.56	0.65				
RA-FN 10	horiz.	Rp 3/8	R 3/8	0.17	0.34	0.47	0.56	0.65				
RA-FN 15	angle	Rp 1/2	R 1/2	0.22	0.43	0.57	0.73	0.90				
RA-FN 15	straight	Rp 1/2	R 1/2	0.22	0.43	0.57	0.73	0.90				
RA-FN 15	horiz.	Rp 1/2	R 1/2	0.22	0.43	0.57	0.73	0.90				
RA-FN 20	angle	Rp 3/4	R 3/4	0.30	0.58	0.83	1.04	1.40				
RA-FN 20	straight	Rp 3/4	R 3/4	0.30	0.58	0.83	1.04	1.40				
RA-FN 20	horiz.	Rp 3/4	R 3/4	0.25	0.50	0.67	0.80	1.00				
RA-FN 25	angle	Rp 1	R 1	0.30	0.58	0.83	1.04	1.40				
RA-FN 25	straight	Rp 1	R 1	0.30	0.58	0.83	1.04	1.40				

1) The  $k_y$ -value indicates the water flow (Q) in  $m^3/h$  at a pressure drop ( $\Delta p$ ) across the valve of 1 bar;  $k_y = Q: \sqrt{\Delta p}$ . The  $k_y$ -value is stated according to EN 215, at Xp = 2K i.e. the valve is closed at 2°C higher room temperature. At lower setings the Xp value is reduced to 0.5K. The  $k_{ys}$ -value states the flow Q at a maximum lift, i.e. at fully open valve.

			Max. pressure <sup>2)</sup>	Max.			
Туре	Design	Work.	Diff.	Test	flow temp.	Code no.	
		bar	bar	bar	°C		
RA-FN 10	angle	10	0.6	16	120	013G0021	
RA-FN 10	straight	10	0.6	16	120	013G0022	
RA-FN 10	horiz.	10	0.6	16	120	013G0141	
RA-FN 15	angle	10	0.6	16	120	013G0023	
RA-FN 15	straight	10	0.6	16	120	013G0024	
RA-FN 15	horiz.	10	0.6	16	120	013G0143	
RA-FN 20	angle	10	0.6	16	120	013G0025	
RA-FN 20	straight	10	0.6	16	120	013G0026	
RA-FN 20	horiz.	10	0.6	16	120	013G0145	
RA-FN 25	angle	10	0.6	16	120	013G0027	
RA-FN 25	straight	10	0.6	16	120	013G0028	

2) Working pressure = static + differential pressure. The maximum differential pressure specified is the maximum pressure atwhich the valves give satisfactory regulation. As with any device which imposes a pressure drop in the system, noise may occur under certain flow/pressure conditions. To ensure quiet operation, maximum pressure drop should not exceed 30 to 35 kPa. The differential pressure can be reduced by the use of the Danfoss differential pressure regulators types AVD, AVDL, AVDS, IVD or ASV-P.



## Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

#### Code nos. and Technical Data for RA-G valves

Туре	Design	Conne ISO	ection 7-1	k <sub>v</sub> -values <sup>1)</sup> [m³/h] P-Band [K]							
	5	Inlet	Outlet	0.5	1.0	1.5	2.0	k <sub>vs</sub>			
RA-G 15	angle	R <sub>p</sub> 1/2	R 1/2	0.54	1.07	1.61	2.06	4.30			
RA-G 15	straight	R <sub>0</sub> 1/2	R 1/2	0.51	0.94	1.35	1.63	2.30			
RA-G 20	angle	R <sub>0</sub> 3/4	R 3/4	0.57	1.11	1.16	2.20	5.01			
RA-G 20	straight	R <sub>0</sub> 3/4	R 3/4	0.54	1.07	1.61	2.06	3.81			
RA-G 25	angle	R <sub>p</sub> 1	R 1	0.59	1.27	1.77	2.41	5.50			
RA-G 25	straight	R 1	R 1	0.57	1.16	1.71	2.27	4.58			

1) The  $k_y$ -value indicates the water flow (Q) in  $m^3/h$  at a pressure drop ( $\Delta p$ ) across the value of 1 bar.

 $k_v = Q: \sqrt{\Delta p}$  The  $k_{vs}$ -value states the flow Q at a maximum lift, i.e. at fully open valve. The  $k_{vs}$ -value

states the flow Q at a maximum lift, i.e. at fully open valve.

Туре			Max. pressure	Max.		
	Design	Work.	Diff. <sup>2)</sup>	Test	flow temp.	Code no.
		bar	bar	bar	°C	
RA-G 15	angle	16	0.20	25	120	013G1676
RA-G 15	straight	16	0.20	25	120	013G1675
RA-G 20	angle	16	0.20	25	120	013G1678
RA-G 20	straight	16	0.20	25	120	013G1677
RA-G 25	angle	16	0.16	25	120	013G1680
RA-G 25	straight	16	0.16	25	120	013G1679

2) Working pressure = static + differential pressure. The maximum differential pressure specified is the maximum pressure at which the valves give satisfactory regulation. As with any device which imposes a pressure drop in the system, noise may occur under certain flow/pressure conditions. To ensure quiet operation, maximum pressure drop should not exceed 30 to 35 kPa. The differential pressure can be reduced by the use of the Danfoss differential pressure regulators.

#### Accessories

Accessories for RA2000 sensors	Code no.
Theft protection plugs, 50 pcs.	013G1232
Temperature range limiting pins, 30 pcs.	013G1237
Scale cover for 013G2920 and 013G2922 tamperproof sensors	013G1233
Toolkit - Allen key and locking pin tool	013G1236
Accessories for RA-FN and RA-G valves	Code no.
Gland seal, 10 pcs.	013G0290
Manual shut-off knob	013G5002
Spare protective cap	013G0275
Service insert DN 15/20*	013G1706
Service insert DN 25*	013G1707

\*RA-G valves only

#### Replacement of gland seal

All Danfoss radiator thermostats manufactured since the early 1960's have gland seals which are replaceable without the need to drain down the system (see p. 7). Replacement sensors for earlier Danfoss thermostats In order to provide a service and upgrade option for earlier RAV and RAVL valve bodies, a range of service sensors is available. Please request details.



Data Sheet Rad	diator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G
----------------	---

## Setting the temperature

The required room temperature is set by turning the setting dial. The temperature scales show the correlation between scale values and the room temperature.

The temperature values stated are for guidance only as the obtained room temperature will often be influenced by installation conditions.

The temperature scales are stated according to European standards at  $Xp = 2^{\circ}C$ . This means that the radiator thermostats close at a sensor temperature which is 2 °C higher than stated on the temperature scales. Locking and limitation of the temperature setpoint of RA sensors are carried out using the limitation pins placed at the back of the sensor.

Locking and max./min limitation of the remote temperature adjuster type RA 5060 are carried out by limiter tabs. The limiter tabs will be covered by the setting dial.

The procedure is described in the instruction, following the product.





## Data Sheet Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

### Setting the temperature

#### Fig. 1: Operating principles of thermostats

The function of the thermostat is to measure the ambient temperature, compare this with the required temperature and correct the valve setting in accordance with the difference. The European Standard EN215 requires that radiator thermostats meet various operating criteria. Danfoss radiator thermostats meet or

exceed these requirements in every respect.

## Fig. 2: Differential pressure dependence

The closing characteristic of a radiator thermostat is depending on the pressure conditions in the valve. Curve 1 applies to the actuator unit without counterpressure from system differential pressure, while curve 2 shows the offset when the counterpressure increases proportionately to the valve closure. The effect is a result of the elasticity of the actuator unit.

#### Fig. 3: Time constant

In order to provide a steady control of the room temperature, a radiator thermostat must respond quickly on temperature variations. The time constant is depending on the specific heat and surface of the sensor.

At a sudden change in ambient temperature at time 0, the thermostat will respond as shown. The time constant is defined as the time used by the spindle for 63% of its full movement.







## Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

## Fig. 4: Flow temperature dependence

Radiator thermostats with built-in sensors might experience flow temperature dependence, when heat is transfered from the valve body to the sensor. The actuator unit responds to a temperature different from the actual room temperature, resulting in a lower temperature than required. Insulating materials for the thermostat base, internal heat shields and high quality product design in positioning the sensing element away from the heat source, help reduce this dependence. Danfoss recommend that radiator thermostat sensors are mounted horizontally, away from the effects of heat rising from hot valve and pipework.

#### Fig. 5: Hysteresis

If the spindle movement of an actuator unit is measured at increasing and then decreasing temperatures, there will be a difference between the point where the valve just closes and the point where it opens again. This difference is termed hysteresis and is caused by friction in the actuator unit and valve body. Hysteresis should be as small as possible.

**Sensor operating principle** The RA2000 thermostatic sensor consists of a bellows system with a saturated vapour charge, which provides proportional control, as opposed to on/off.

The sensor is actuated by ambient temperature changes. The calibrated pressure in the bellows corresponds to the temperature of the charge. This pressure is balanced by the force of a regulating spring.

On a rise in ambient temperature, the vapour pressure increases inside the bellows, moving the valve cone towards the "closed" position.

On a drop in ambient temperature, the vapour pressure falls, allowing the bellows to contract and the valve cone to move towards the "open" position.

The vapour charge will always condense at the coldest part of the sensor, usually furthest away from the valve body. The radiator thermostat will therefore always respond to changes in room temperature and will not be affected by the system water temperature.

However, when the air around the sensor is heated by the hot valve body and pipework, then the sensor can detect a temperature higher than the room temperature. To avoid this, Danfoss recommend that the sensor is mounted horizontally whenever possible.









## Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

#### Sensor operating principle



- 1. Thermostatic element
- 2. Bellows
- 3. Setting dial
- 4. Setting spring
- 5. Pressure pin
- 6. O-ring seal
- 7. Valve body
- 8. Valve cone
- 9. Nozzle

## Hydraulic balance



To ensure that the valve capacity of a fully opened valve is not significantly greater than that at 2 degrees C P-deviation, all RA-FN valves have a modified valve characteristic. This improved valve characteristic maintains hydraulic balance during start-up.

## Definitions

## k<sub>v</sub>-coefficient of flow

The k<sub>y</sub>-value is a measure for the quantity of liquid in m<sup>3</sup>/h that the valve will pass with a pressure drop of 1 bar across the valve. The k<sub>y</sub>-value is used in the following formulae to calculate flow rates for valve sizing purposes.

$$Q = k_v \sqrt{\Delta p}$$
 or  $\Delta p = \left[\frac{Q}{k_v}\right]^2$  or  $k_v = \frac{Q}{\sqrt{\Delta p}}$ 

where: Q

= flow of liquid in **m<sup>3</sup>/h** 

**k** = flow coefficient

**Δp** = differential pressure (pressure drop) across the valve in **bar** 



#### Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

#### Proportional band

The purpose of a proportional temperature controller is to respond to any deviation from a set temperature level by opening or closing the heat input, until the required room temperature is achieved.

The difference from the set temperature, which is necessary for the controller to change from closed to open (or vice versa), is called the proportional band or just P-band. This is measured in K (°C).

A Danfoss radiator thermostat operates with a small P-band of only 0.5K-2K, which ensures lesser deviations from the set room temperature than conventional room thermostats.

#### Capacities





Capacity with P-band between 0.5K and 2K with RA 2000 sensor.



Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G





Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G



*Note:* As with any device which imposes a pressure drop system, noise may occur under certain flow/ pressure conditions. To ensure quiet operation, maximum pressure drop should not exceed 40 to 45 kPa

#### Example

Heat requirement: 2.05 kW Temperature drop: 11 °C Differential pressure across the radiator: 0.05 bar (5 kPa)

Solution

Water flow through the radiator per hour:

$$Q = \frac{2.05}{4.2 \times 11} = 0.044$$
 l/s

The P-band value depends on the chosen valve, i.e. RA-FN 15 will work with a P-band of 2K. RA-FN 20 will work with a P-band of about 1.4K.

The  $k_{\rm v}\mbox{-}{\rm value}$  can also be calculated on the basis of this formula:

$$k_{v} = \frac{Q}{\sqrt{\Delta p}}$$
  

$$0.044 = \frac{0.044 \times 3600}{1000} = 0.158 \text{ m}^{3}/\text{h}$$
  

$$k_{v} = \frac{0.158}{\sqrt{0.05}} = 0.71$$

Note: 1 m<sup>3</sup>/h = 0.278 l/s

## Data Sheet Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

## Choose the right sensor

Always choose a type of thermostatic sensor, which is able to detect the temperature of the ambient air.

Radiator thermostats with built-in sensors should always be fitted horizontally so that the ambient air can pass freely over the sensor.

Danfoss does not recommend the fitting of a builtin sensor in vertical position, because heat transfer from the valve body and possibly surface pipes will cause incorrect operation of the thermostat.

Radiator thermostats with remote sensor should be used when:

- Curtains cover the sensor
- Sensor is affected by surface pipes
- Sensor is affected by draught
- It is necessary to mount the sensor in vertical position.

The remote sensor must be mounted on the wall, away from curtains, or on the skirting board beneath the radiator, if free of surface pipes.

All remote sensors are supplied with a ultra-thin capillary tube. Simply pull out the required length and fix the tube using clips provided or a special tacker gun.

Radiator valves with remote adjustment - the remote temperature adjuster is used on radiators or convectors, which are hidden in a cabinet or in other ways inaccessible to the user. In addition, the room temperature adjuster is used in integral sockets and installation ducts.

The sensor and the setting part of a remote setting unit are integrated.

The remote temperature adjuster is placed in an easily accessible place, where the ambient air can pass freely over the sensor. The remote temperature adjuster should be mounted 1.2 to 1.6 m above the floor.







## **Replacing the gland seal**





If a valve begins leaking from the gland seal, the seal can be easily replaced while the system is in operation.

Use a KW 10 spanner to remove the old gland seal and to tighten the new.

#### Dimensions



RA2000 built-in sensor on RA-FN or RA-G valve



RA2000 built-in sensor on RA-FN valve, horizontal angle



RA2000 remote sensor on RA-FN or RA-G valve



RA2000 remote temperature adjuster



## Radiator thermostats type RA2000, valve bodies type RA-FN (series D) and RA-G

Туре	ISO	7-1							L <sub>7</sub>	L <sub>8</sub>	L <sub>9</sub>	L <sub>10</sub>	Arc. flats	
	D	d <sub>2</sub>		L <sub>2</sub>	L <sub>3</sub>	L <sub>4</sub>	L <sub>5</sub>	L <sub>6</sub>					S <sub>1</sub>	S <sub>2</sub>
RA-FN 10	Rp 3/8	R 3/8	60	85	27	52	22	47	96				22	27
RA-FN 10 horiz.	Rp 3/8	R 3/8						61	110	26	51	22	22	27
RA-FN 15	Rp 1/2	R 1/2	67	95	30	58	26	47	96				27	30
RA-FN 15 horiz.	Rp 1/2	R 1/2						60	111	29	57	27	27	30
RA-FN 20	Rp 3/4	R 3/4	74	106	34	66	29	47	96				32	37
RA-FN 20 horiz.	Rp 3/4	R 3/4						61	110	34	66	30	32	37
RA-FN 25	Rp 1	R 1	90	125	40	75	34	52	101				41	46
RA-G 15	Rp 1/2	R 1/2	68	96	30	58	27	50	99				27	30
RA-G 20	Rp 3/4	R 3/4	74	106	34	66	30	50	99				32	37
RA-G 25	Rp 1	R 1	90	126	42	78	34	54	103				41	46

Danfoss A/S Heating Segment

Haarupvaenget 11 8600 Silkeborg Denmark Phone:+45 7488 8000 Fax: +45 7488 8100 Email: heating.solutions@danfoss.com www.heating.danfoss.com

Danfoss can accept no responsibility for possible errors in catalogues, brochures and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.